



CERTIFICATE

Product Certificate

ET-0406-24



Inspecta Estonia OÜ has granted a product certificate to attest that the product

Corrugated double wall cable conduits for buried underground applications

placed on the market by

Pipelife Eesti AS

Põrguvälja tee 4, Lehmja küla, 75306 Rae vald, Harju maakond, ESTONIA

and produced in the factory

Pipelife Eesti AS

Põrguvälja tee 4, Lehmja küla, 75306 Rae vald, Harju maakond, ESTONIA

has following performances:

Nominal outside diameter dn (mm)	Resistance to compression		Resistance to impact (class)	Resistance to bending
	Minimum force (N)	Type		
50 - 160	450	450	L	Pliable
50 - 160	450	450	N	Pliable
50 - 160	450	450	L	Rigid
50 - 160	450	450	N	Rigid
50 - 160	750	750	L	Rigid
50 - 160	750	750	N	Rigid
110	1250	750	N	Rigid

The company has a working product management system that has been implemented in accordance with the requirements of **EN 61386-24:2010, EN 61386-1:2008 and EN 61386-1:2008/A1:2019**

The manufacturer is testing the samples taken at the factory in accordance with prescribed test plan. Inspecta Estonia OÜ has performed type testing, the initial inspection of the factory and of the factory production control and performs the continuous surveillance, assessment, and approval of the factory production control.

This certificate is issued on **29.07.2024** and remains valid until **28.07.2029** as long, as the manufacturing conditions in the factory or the FPC itself are not modified significantly. The validity of the certificate can be checked on the Internet at www.kiwa.com/ee.

German Vimb
on behalf of Inspecta Estonia OÜ

Tallinn 29.07.2024



Inspecta Estonia OÜ

Mäealuse 2/4

12618 Tallinn

EESTI

Tel. +372 659 9470

estonia@kiwa.com

www.kiwa.com/ee