




## CERTIFICATE NCS/FI 27899

Our Ref. 269099-2

<b>Product</b>	Installation conduit, pliable
<b>Type</b>	TAM 16 TAM 20 TAM 25
<b>Trade mark</b>	PIPELIFE
<b>Certificate Holder/ Manufacturer</b>	Pipelife Finland Oy Mustikkakankaantie 1 FI-91600 UTAJÄRVI FINLAND
<b>Technical information</b>	Sizes 16, 20 and 25 mm, corrugated conduit Classification 334122400010- Temperature range -25/+60°C
<b>The product is certified according to the following standard(s)</b>	EN 61386-1:2008 EN 61386-22:2004 + A11:2010
<b>Validity</b>	This certificate is valid until 14 February 2018 unless the standard in question has been amended or superseded with significant changes in requirements, in which case, SGS Fimko has the right to shorten the validity of the certificate based on the legislation of the European Union. This certificate includes the right to use the FI mark under the condition that changes (if any) will be checked at SGS Fimko before the product is brought onto market and that the conditions for FI certification are met.
<b>Directive information</b>	The product(s) fulfils the essential safety requirements for CE conformity marking according to the Low Voltage Directive (2006/95/EC) at the date of issue of the certificate.
<b>Date of issue</b>	14 February 2013
<b>Signature</b>	<b>SGS Fimko Ltd</b>  Sixten Lökfors Project Manager



This certificate has 1 appendix



This certificate is issued by the company under its General Conditions for Certification Services accessible at <http://www.sgs.fi/en/Terms-and-Conditions.aspx>. Attention is drawn to the limitations of liability defined therein and in the Test Report here above mentioned which findings are reflected in this certificate. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law.



**Manufacturing site(s)** Pipelife Finland Oy  
Mustikkakankaantie 1  
FI-91600 UTAJÄRVI  
FINLAND

**Additional information** This certificate replaces NCS/FI certificate No. 24513 dated 18 September 2008, due to updated standard.

Supplement to Certificate: NCS/FI 27899

Internal ref.  
Sixten Lökfors

14 February 2013

## NORDIC CERTIFICATION SERVICE

We hereby confirm that the product(s) appearing from the certificate with above certificate reference also comply(ies) with requirements for secondary certification in the following countries: Norway, Sweden

### NOTIFICATION

<b>Certificate holder for Norway, Sweden</b>	Pipelife Finland Oy Mustikkakankaantie 1 FI-91600 UTAJÄRVI FINLAND
	Please send the invoice and the certificate directly to Certificate Holder, Attn: Mr Jarno Sihvo, mailto: <a href="mailto:jarno.sihvo@pipelife.fi">jarno.sihvo@pipelife.fi</a>
<b>Safety standard(s) applied</b>	EN 61386-1:2008 EN 61386-22:2004 + A11:2010
<b>Deviations</b>	Not applicable
<b>EMC requirements</b>	-
<b>The assignment is based on</b>	Testing in own premises from SGS Fimko Ltd.
<b>Limitations or reservations regarding the testing / examination performed</b>	None
<b>Certification marks</b>	Affixing of the certification mark(s) of the Nordic body(ies) on the product must not take place before notice about national certification is received from the individual body.
<b>Production surveillance</b>	Will be carried out by SGS Fimko according to agreed procedures.
<b>Other information</b>	Copy of the certificate, this Notification and other agreed documentation are transferred directly from SGS Fimko to NEMKO and SEMKO.
<b>Test samples must be submitted to the secondary body(ies)</b>	No
<b>Date of issue</b>	14 February 2013

This Notification may be challenged if it is more than 3 years old.

### SGS Fimko Ltd

Signature



Sixten Lökfors  
Project Manager